

**TASK FORCE EFFORT –780CMR2603.7--5-04-10**

Amend Chapter 26, section 2603.7 by adding an EXCEPTION which reads:

**EXCEPTION:** Foam plastics shall not be permitted in A-2 use occupancies unless the room or space in which the foam plastics are installed is/are equipped with an automatic fire suppression system in accordance with section 904.3

**DEFENSE:**

Unsprinklered A-2 use life safety performance in fire emergencies has been tragically demonstrated to be unsatisfactory